

## ***EU Declaration of Conformity***

Henry Technologies hereby declare under our sole responsibility that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with Sound Engineering Practice (SEP) as designated in Article 4 Para. 3 of the Pressure Equipment Regulations (European Directive 2014/68/EU)

### ***Description of Pressure Equipment: Moisture Indicators***

**Models covered:** MI-30-1/4F, MI-30-3/8F, MI-30-1/2F,  
MI-30-1/4S, MI-30-3/8S, MI-30-1/2S, MI-30-5/8S, MI-30-7/8S, MI-30-1.1/8S

### ***Conformity & Assessment Procedure Followed:***

<b>Category</b>	<b>SEP</b>
<b>Module</b>	<b>N/A</b>
<b>Certificate</b>	<b>N/A</b>
<b>DN</b>	<b>&lt;32mm</b>

<b>Classified for</b>	<b>Group 2 Gases</b>
<b>Design Pressure</b>	<b>34.5 Bar</b>
<b>Maximum Op. Temp</b>	<b>+93° C</b>
<b>Minimum Op. Temp</b>	<b>-10° C</b>

The following transposed European standards and other technical specifications have been used:

UL 207

**Notified Body: N/A**

Signed: *Ronnie Crancher*

Quality Manager

Date: 12/11/18



(Responsible Person - Name and actual Title)

1 DOC 057 Rev A18

A subsidiary of Henry Group Industries Limited