

## ***EU Declaration of Conformity***

Henry Technologies hereby declare under our sole responsibility that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with Sound Engineering Practice (SEP) as designated in Article 4 Para. 3 of the Pressure Equipment Regulations (European Directive 2014/68/EU)

### ***Description of Pressure Equipment: Suction Line Accumulators***

***Models covered:*** S-7043, S-7044, S-7045, S-7046, (includes HE & HP Suffix).

### ***Conformity & Assessment Procedure Followed:***

<b>Category</b>	<b>SEP</b>
<b>Module</b>	<b>N/A</b>
<b>Certificate</b>	<b>N/A</b>
<b>PV</b>	<b>&lt; 50</b>

<b>Classified for</b>	<b>Group 2 Gases</b>
<b>Design Pressure</b>	<b>31.0 Bar</b>
<b>Maximum Op. Temp</b>	<b>+80° C</b>
<b>Minimum Op. Temp</b>	<b>-30° C</b>

\* For all S- Models, a de-rated MWP applies for operating temperatures below -10 ° C. For further information contact Henry Technologies.

The following transposed European standards and other technical specifications have been used:

UL 207

Notified Body : N/A

Signed: *Ronnie Crancher*

Quality Manager

Date: 12/11/18



(Responsible Person - Name and actual Title)