

## EU Declaration of Conformity

Henry Technologies hereby declare under our sole responsibility that the Pressure Equipment listed below has been designed, manufactured and tested in accordance with the requirements of the Pressure Equipment Regulations (European Directive 2014/68/EU)

### Description of Pressure Equipment: Suction Line Accumulators

Models covered: S-7731, S-7731HE, S-7732, S-7732HE

### Conformity & Assessment Procedure Followed:

Category	IV
Module	B + D
Certificates	CE-0041-PED-B-HEN 001-12-GBR CE-0041-PED-D-HEN 001-18-GBR
PV	<1000 - ≤3000

Classified for	Group 2 Gases
Design Pressure	31.0 Bar
Maximum Op. Temp	+80° C
Minimum Op.Temp	-30° C

\* For all S- Models, a de-rated MWP applies for operating temperatures below -10 °C. For further information contact Henry Technologies.

The following transposed European standards and other technical specifications have been used:

UL 207

#### Notified Body:

The Notified Body which inspected the manufacturer's quality assurance system:

**Bureau Veritas UK Ltd.**  
2<sup>nd</sup> Floor Atlantic House  
Atlas Business Park  
Wythenshawe  
Manchester M22 5PR  
Notified Body identification No. **0041**

Signed: *Ronnie Crancher*

Quality Manager

Date 12/11/18



(Responsible Person - Name and actual Title)